

DEPARTMENT OF PURCHASING AND CONTRACTING
EVALUATION SUMMARY

Criteria					
Proposers	Project Approach	Project Schedule	Design-Builder/Subcontractor/Other-Firms	Key Personnel	LSBE Points
Morgan Contracting	<ul style="list-style-type: none">o Thier plan went into very detailed explanation of the equipment selected and why as well as recommendations to supplement the design that were not required in the RFP.o Discrepancy for the channel structure modification, in the proposed drawing didn't indicate any channel structure modificationo The submittal provides sufficient information on the design management plan for collaboration with the Countyo The submittal provides sufficient information on the design management plan for collaboration with the Countyo Contractor compared two technologies then explained how they determined their equipment selection	<ul style="list-style-type: none">o Contractor provided a schedule on how they would approach 60%, 90% and 100%o Identified risk management strategy of a risk managemant registry with the risk being assigned to the proper personel.o Documents included all necessary schedule and risk assessment components.o The duration for design and construction are reasonable and good per the required time in the RFP.o Timeline seems to identify the key milestones of the project while providing an reasonable number of days to complete the project	<ul style="list-style-type: none">o 65% of work will be done by Morgano Firms identified clearly with responsibilities. Builder had 1 project involving UV disinfection systems that has not bee completed.o The documents show adequate information on the design and builder teams, organizational chart, and identifies all subconsultants.o R&C InfraTech LSBE subcontractor has performed many design projects with DC/DWM.o Need more information on subcontractors experience	<ul style="list-style-type: none">o Resumes were submitted and everyone had 10 or more years of experienceo All key personel and responsibilities identified. Have experience with their respective duties except for specific UV disinfections.o All staff meet with required experience and project scope.o Most of the reference projects from this sub in the proposal have many design errors and being scored as the fair rate.o Key personnel experience was good.	<ul style="list-style-type: none">o LSBE DeKalb: 20%o LSBE MSA: 0%o Total LSBE Points: 10