



DEKALB COUNTY GOVERNMENT
PLANNING DEPARTMENT

The following areas below may warrant comments from the development Division. Please respond accordingly as the issues relate to the proposed request and the site plan enclosed as it relates to Chapter 14. You may address applicable disciplines.

DEVELOPMENT ANALYSIS:

• **Transportation/Access/Row**

Consult the DeKalb County Transportation Department prior to land development permit. Verify widths from the centerline of the roadways to the property line for possible right-of-way dedication. Improvements to include sidewalk within the right-of-way may be required as a condition for building permit application review approval. Safe vehicular circulation is required. Paved off-street parking is required. The recorded final plat indicates vehicular access is prohibited from the lot to and from Cavanaugh Avenue.

• **Storm Water Management**

Compliance with the Georgia Stormwater Management Manual, DeKalb County Code of Ordinances 14-40 for Stormwater Management and 14-42 for Storm Water Quality Control, to include Runoff Reduction Volume where applicable is required as a condition of land development permit approval. Use Volume Three of the G.S.M.M. for best maintenance practices. Use the NOAA Atlas 14 Point Precipitation Data set specific to the site. Recommend Low Impact Development features/Green Infrastructure be included in the proposed site design as much as practicable.

• **Flood Hazard Area/Wetlands**

The presence of FEMA Flood Hazard Area was not indicated in the County G.I.S. mapping records for the site; and should be noted in the plans at the time of any land development permit application. Encroachment of flood hazard areas require compliance with Article IV of Chapter 14 and FEMA floodplain regulations.

- **Landscaping/Tree Preservation**

Landscaping and tree preservation plans for any building lot must comply with DeKalb County Code of Ordinances 14-39 as well as Chapter 27 Article 5 and are subject to approval from the County Arborist.

- **Tributary Buffer**

State water buffer was reflected in the G.I.S. records for the site. Typical state waters buffer have a 75' undisturbed stream buffer and land development within the undisturbed creek buffer is prohibited without a variance per DeKalb County Code of Ordinances 14-44.1.

- **Fire Safety**

Plans for land development permit must comply with Chapter 12 DeKalb County Code for fire protection and prevention.

COMMENTS FROM TRANSPORTATION DIVISION

Zoning Comments (Jan 2019)

N1. No comment.

→ N2. Engineer must verify sight distance when placing driveways.

N3. No Comment.

N4 & N5. Rock Chapel Road is State Road 124. GDOT review and approval required prior to issuing any permits. GDOT Contact: Justin Hatch at juhatch@dot.ga.gov Minor Arterial. Refer to Section 14-190 of the Land Development Code and Chapter 5.4.3 of the Zoning Code for infrastructure requirements. No acceleration lane. Prefer deceleration lane. Verify driveway placement to ensure required sight distance requirements are met based on the speed limit and curvature of roadway. 6 foot sidewalk. Street lights required.

N6. No Comment.

N7. Refer to Section 14-190 of the Land Development Code and Chapter 5.4.3 of the Zoning Code for infrastructure requirements. Tilson Road is classified as a collector street. Right of way dedication of 35 feet from centerline, 6 foot sidewalks, street lights, bike lanes required. Verify driveway placement to ensure required sight distance requirements are met based on the speed limit and curvature of roadway. Interior streets to be local- 55 foot right of way, five foot landscape strip, 5 foot sidewalk, street lights required.

N8. Refer to Section 14-190 of the Land Development Code and Chapter 5.4.3 of the Zoning Code for infrastructure requirements. River Road is classified as a minor arterial. Right of way dedication of 35 feet from centerline, 6 foot sidewalks, street lights, bike lanes required. Verify driveway/roadway placement to ensure required sight distance requirements are met based on the speed limit and curvature of roadway. Interior streets to be local- 55 foot right of way, five foot landscape strip, 5 foot sidewalk, street lights required.

N9. Cook Road is within the GDOT I-20 Right of Way. GDOT review and approval for access is required prior to issuing any permits. GDOT Contact: Justin Hatch at juhatch@dot.ga.gov . Construct sidewalks up to Flat Shoals Road within the existing right of way.

N10. No comment.

N11. No comment.

N12. No comment.

N13. No comment.

N14. Candler Road is State Route 155. GDOT review and approval required prior to permitting. GDOT Contact: Justin Hatch at juhatch@dot.ga.gov GDOT review and approval for access is required prior to issuing any permits.

N15. Covington Hwy is a State Route. GDOT review and approval for access is required prior to issuing any permits. GDOT Contact: Justin Hatch at juhatch@dot.ga.gov . Refer to Section 14-190 of the Land Development Code and Chapter 5.4.3 of the Zoning Code for infrastructure requirements. Covington Hwy is classified as a major arterial. Right of way dedication of 50 feet from centerline, 6 foot sidewalks,