



Legislation Details (With Text)

File #: 2018-1809 **Version:** 1 **Name:**

Type: Resolution **Status:** Preliminary Item

File created: 3/8/2018 **In control:** Board of Commissioners

On agenda: 4/10/2018 **Final action:** 4/10/2018

Title: Commission District(s): All
CO - Change Order No. 1 to Contract No. 1085915 Water Filter Removal, Repair, Replacement, and Maintenance at Scott Candler Water Filter Plant: for use by the Department of Watershed Management (DWM). This contract consists of the removal, repair, replacement and maintenance of water filters. Awarded to Griffin Bros. Inc. Amount Not To Exceed: \$78,316.36.

Indexes:

Attachments: 1. Agenda Notes, 2. Change Order Request

Date	Ver.	Action By	Action	Result
4/10/2018	1	Board of Commissioners	approved	Pass
4/3/2018	1	PWI-Public Works & Infrastructure Committee	recommended for approval.	Pass
4/3/2018	1	Committee of the Whole		

Purchasing Type: Change Order (CO)

Public Hearing: YES NO **Department:** Purchasing & Contracting

AGENDA ITEM:

Commission District(s): All

CO - Change Order No. 1 to Contract No. 1085915 Water Filter Removal, Repair, Replacement, and Maintenance at Scott Candler Water Filter Plant: for use by the Department of Watershed Management (DWM). This contract consists of the removal, repair, replacement and maintenance of water filters. Awarded to Griffin Bros. Inc. Amount Not To Exceed: \$78,316.36.

Information Contact: Talisa Clark, CPPO

Phone Number: (404) 687-2797

PURPOSE:

Awarded by the BOC on October 10, 2017 for an amount not to exceed \$1,806,075.62. The request is for additional funding needed for additional repairs discovered during the manufacturer’s inspection. The additional repairs specifically include the following: installation of grout to perimeter of filter 1A, 1B, 11A and 11B between the underdrain and the wall; replacement of anchor bolts in filter 1A and 11A; removal of high spots in filter 1A; removal of grout that ran underneath underdrains in filter 1A; adding a second nut to all anchor bolts in filters 1A, 1B, 11A and 11B; and addition of grout to raise the underdrain support in filter 11A. This request will also cover re-mobilization costs of the contractor after completion of the additional repairs and other repairs identified by the construction management team.

RECOMMENDATION:

Recommend approval of Change Order No. 1 to increase the contract amount with:

Griffin Bros. Inc., 103 Griffin Drive, Maysville, GA 30558

Amount Not To Exceed: \$78,316.36

ADDITIONAL INFORMATION:

- | | |
|------------------------------|-------------------|
| 1. LSBE Participation: | 20% |
| 2. Contract Effective Date: | January 8, 2018 |
| 3. Contract Expiration Date: | December 31, 2018 |
| 4. Amount Spent To Date: | \$0.00 |
| 5. Funding: | Enterprise (DWM) |