



Legislation Details

File #: 2021-3301 **Version:** 1 **Name:**
Type: Resolution **Status:** Action
File created: 10/21/2021 **In control:** Board of Commissioners
On agenda: 12/14/2021 **Final action:** 12/14/2021
Title: Commission District(s): 1 & 6
CO - Change Order No. 4 to Contract No. 1119346 Design Build Services for Scott Candler Water Treatment Plant - High Services Pump Station (HSPS) Header & Transfer Pumps Replacement: for use by the Department of Watershed Management (DWM). This contract consists of providing design and construction services to remove and replace the transfer pump station's main intake header, which is showing severe signs of corrosion, and to include the removal and replacement of four (4) small transfer pumps with two (2) large variable frequency drive (VFD) transfer pumps for increased efficiency and capacity of the water distribution system. This request is to increase the contract term through December 31, 2022 to allow for the completion of existing scope of work. Awarded to Reeves Young, LLC. CONTRACT TERM INCREASE ONLY.

Indexes:

Attachments: 1. 2021-3301 Agenda Notes, 2. 2021-3301 UD CO4 Request

Date	Ver.	Action By	Action	Result
12/14/2021	1	Board of Commissioners	approved	Pass
11/16/2021	1	PWI-Public Works & Infrastructure Committee	recommended for approval.	Pass
11/16/2021	1	Board of Commissioners		
11/16/2021	1	Board of Commissioners		