



Legislation Text

File #: 2023-1225, **Version:** 1

Purchasing Type: Request for Proposals (RFP)

Public Hearing: YES NO **Department:** Purchasing & Contracting

AGENDA ITEM:

Commission District(s): All

RFP - Request for Proposals No. 23-500640 Design and Engineering Services Upgrade Lower Crooked Creek No. 2 (LCC 2) Pump Station: for use by the Department of Watershed Management (DWM). Consists of providing design and engineering services for the upgrade of LCC 2 Pump Station (PS), upgrade of Rogers Lake PS, and decommissioning of LCC No. 3 PS. Recommend award to the highest scoring proposer: Lakeshore Engineering, LLC. Total Amount Not to Exceed \$35,593,331.00.

Information Contact: Michelle Butler, Procurement Manager

Phone Number: (404) 687-3581

PURPOSE:

Consist of providing design and engineering services for replacing the existing LCC 2 PS, demolition of the existing LCC 2 and LCC 3 PSs, upgrading or replacing the Rogers Lake PS, and connecting to the Rogers Lake PS discharge location (manifolded force main connection), and the interconnection of the LCC 2 and LCC 3 force mains (24" to 24"). These services will assist DWM with meeting the demands of the County by providing engineering services to increase the Snapfinger facility permitted capacity from forty-four (44) million gallons per day (MGD) to fifty-four (54) MGD. Three (3) proposals were received.

RECOMMENDATION:

Recommend award to the highest scoring proposer:

Lakeshore Engineering, LLC, 1259 Ellsworth Drive, Atlanta, GA 30318

and authorize the Chief Executive Officer to execute the contracts and all associated documents.

Evaluation Committee Scores:

Firm:

Lakeshore Engineering, LLC
Ruby Collins, Inc.

Score:

92 points
77 points

ADDITIONAL INFORMATION:

1. Contract Effective Date: Contract Execution
2. Contract Effective Date: December 31, 2027
3. Funding: Renewal and Extension

CIP Line No. 84 (DWM)

4. Additional Proposers:

Ruby Collins, Inc.
4875 Martin Court, SE
Smyrna, GA 30082

Reeves Young, LLC
45 Peachtree Industrial Blvd
Sugar Hill, GA 30518
(Non-Responsive)