



DeKalb County Government

Manuel J. Maloof Center
1300 Commerce Drive
Decatur, Georgia 30030

Legislation Details (With Text)

File #: 2020-0740 **Version:** 1 **Name:**
Type: Resolution **Status:** Preliminary Item
File created: 6/29/2020 **In control:** Board of Commissioners
On agenda: 7/28/2020 **Final action:**
Title: Commission District(s): All
SS - Purchase of two (2) Model 395L 84" McCrometer finished water flow meters (Sole Source): for use by the Department of Watershed Management (DWM). Consists of providing accurate measurements of the volumes of potable water discharged by the Scott Candler Water Treatment Plant. These measurements are required by the State of Georgia. Awarded to The Avanti Company. Amount Not To Exceed: \$116,607.00.

Indexes:

Attachments: 1. AGENDA NOTES Avanti, 2. 2020-0740 Sole Source, 3. Quotation Avanti

Date	Ver.	Action By	Action	Result
7/28/2020	1	Board of Commissioners	approved	Pass
7/21/2020	1	PWI-Public Works & Infrastructure Committee	recommended for approval.	Pass
7/21/2020	1	Committee of the Whole	Accepted to the BOC agenda and assigned	

Purchasing Type: Sole Source (SS)

Public Hearing: YES ☐ NO ☒

Department: Purchasing & Contracting

AGENDA ITEM:

Commission District(s): All

SS - Purchase of two (2) Model 395L 84" McCrometer finished water flow meters (Sole Source): for use by the Department of Watershed Management (DWM). Consists of providing accurate measurements of the volumes of potable water discharged by the Scott Candler Water Treatment Plant. These measurements are required by the State of Georgia. Awarded to The Avanti Company. Amount Not To Exceed: \$116,607.00.

Information Contact: Cathryn G. Horner, Chief Procurement Officer

Phone Number: (404) 371-6334

PURPOSE:

The State of Georgia requires DeKalb County to accurately measure the volume of potable water discharge by the Scott Candler Water Treatment Plant. The McCrometer finished water flow meters are Full Profile Insertion (FPI) Mag Meters that can be installed on the County's preexisting taps to replace the two (2) inaccurate Venturi meters without service interruptions. Purchasing McCrometer finished water flow meters will prevent the County from paying construction cost due to line shutdown.

RECOMMENDATION:

Recommend approval of the sole source with:

The Avanti Company, 22 South Lake Avenue, Avon Park, FL 33825

Amount Not To Exceed: \$ 116,607.00

ADDITIONAL INFORMATION:

- | | |
|------------------------------|---------------------------|
| 1. Contract Effective Date: | N/A |
| 2. Contract Expiration Date: | N/A |
| 3. Total Spent To Date: | N/A |
| 4. Funding: | General - Operating (DWM) |