



## Legislation Details (With Text)

**File #:** 2021-2395    **Version:** 1    **Name:**  
**Type:** Resolution    **Status:** Preliminary Item  
**File created:** 3/23/2021    **In control:** Board of Commissioners  
**On agenda:** 4/27/2021    **Final action:** 4/27/2021  
**Title:** Commission District(s): All  
LB - Invitation No. 20-101321 Snapfinger Creek Advanced Wastewater Treatment Facility Nord Helical -Bevel Gear Motors (One Time Buy) (DWM). Consists of the purchase and replacement of five (5) Nord Helical - Bevel Gearmotors. One (1) bid was received. Recommend award to the sole, responsive and responsible bidder: Cole Electric Technology Inc. Amount Not To Exceed: \$129,132.80.

### Indexes:

**Attachments:** 1. 2395 Agenda Notes, 2. 2395 Recommendation, 3. 2395 Bid Tabulation, 4. 2395 Market Survey

Date	Ver.	Action By	Action	Result
4/27/2021	1	Board of Commissioners		
4/20/2021	1	PWI-Public Works & Infrastructure Committee	recommended for approval.	Pass
4/20/2021	1	Committee of the Whole	Accepted to the BOC agenda and assigned	

**Purchasing Type:** Low Bidders (LB)

**Public Hearing:** YES ☐ NO ☒

**Department:** Purchasing & Contracting

### AGENDA ITEM:

**Commission District(s):** All

LB - Invitation No. 20-101321 Snapfinger Creek Advanced Wastewater Treatment Facility Nord Helical-Bevel Gear Motors (One Time Buy) (DWM). Consists of the purchase and replacement of five (5) Nord Helical - Bevel Gearmotors. One (1) bid was received. Recommend award to the sole, responsive and responsible bidder: Cole Electric Technology Inc. Amount Not To Exceed: \$129,132.80.

**Information Contact:** Cathryn G. Horner, Chief Procurement Officer

**Phone Number:** (404) 371-6334

### PURPOSE:

Consists of the purchase and replacement of five (5) Nord Helical - Bevel Gearmotors. The previous units were installed at the facility in 2019 and have stopped working due to failed motors or gearboxes. The gear motors are needed to operate the aeration brushes at the aeration tanks to satisfy the daily demand of the peak flow and major storm conditions. The gear motors are vital to the facility operations to remove ammonia from the wastewater.

### RECOMMENDATION:

Recommend award to the sole, responsive and responsible bidder:

Cole Electric Technology Inc., 3980 Martin Luther King Jr. Dr., Atlanta, GA 30336

Amount Not To Exceed: \$129,132.80

**ADDITIONAL INFORMATION:**

1. Funding: Enterprise - Operating (DWM)